

Operating Policy Regarding Electrical Inspections

1. All new installations, regardless of size or nature of use, will require inspection.
2. Disconnected services, regardless of type, must be inspected if disconnected for 12 months or more.
3. Temporary boards/services provided by customer or builder will require inspection when new and before reconnecting.
4. Oil Wells- Will require inspection when new and before reconnecting.
5. Any service will be inspected before reconnecting when disconnected for:
 - a. Fire
 - b. At the request of the member for purpose of repair or replacement or parts.
 - c. If determined unsafe by Inter-County Energy personnel.
6. Reconnects on mobile homes will be inspected only if the wiring between the meter pole and mobile home has been installed or replaced, or a different mobile home is in place from the last time a service was active.